

# PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 328

Dated: 18.04.2024


It is certified that an inspection team headed by Dr. Rakesh Kumar Yadav Dy. CMO  
(Name of Officers with designation) from CMO office Raebareilly UP. PHED inspected the  
New Standard Public School, Tripula Raebareilly  
on 16.04.2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing  
no. T.R.F. - 0242 dated 11.4.2024 of Universal Research Laboratory  
Services, Lucknow (PHED Lab) certified  
that the New Standard Public School, Tripula, Raebareilly UP.  
has safe drinking water facilities for the students and members of staff of the institution. School is  
also maintains the hygienic sanitation condition in the school building & the campus as per norms  
prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 17.04.2026

Signature with Seal: 

Name: Dr. Rakesh Kumar Yadav


Designation: A.C.M.O.

Name & Address of the Office / Department: 

To  
New Standard Public School  
Tripula Raebareilly UP.

**Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies**

मेरा वोट, मेरी पहचान,  
20 मई को करें मतदान



**Principal**  
New Standard Public School  
Sr. Sec. School  
Tripula-Raebareilly



**MANAGER**  
New Standard Public School  
Tripula, Raebareilly



**TEST REPORT**

Sample Code: URLS24-0434		ULR No: TC12484240000384F	Issued On: 15.04.2024
1.	Name & Address of Customer	New Standard Public School Senior Secondary School ; Tripula Chauraha, Raebareli Uttar Pradesh.	
2.	Reference No.	TRF-0242; Dated 11.04.24	
3.	Material Identification with Details	Water; 1 Litre.	
4.	Source / Location	Ground Water/ Tank- School Permise	
5.	Sampled by / Sample Condition	Customer / Sealed & Satisfactory	
6.	Sampling Plan & Procedure	NA	
7.	Date / Time of Sampling	NA	
8.	Date of Sample Registration	11.04.2024	
9.	Date of Sample Testing	12.04.2024 to 15.03.2024	
10.	Environmental Conditions	Room Temperature (°C): 24.6	Relative Humidity (%): 47

**RESULTS**

S. No.	Name of Test	Test Result	Units	IS 10500:2012 Drinking Water Specification	Method of Test
Discipline- Chemical					
Group- Water					
1	Odour	Agreeable	-	Agreeable (No Relax.)	IS:3025 (Part 05) 2018
2	Taste	Agreeable	-	Agreeable (No Relax.)	IS:3025 (Part 08) 2023
3	Turbidity	BLQ (LOQ=0.1)	NTU	1.0 (Max. 5.0)	IS:3025 (Part 10) 1984
4	pH value	7.83	-	6.5-8.5 (No Relax.)	IS:3025 (Part 11) 2022
5	Total Dissolved Solids	355	mg/l	500 (Max.2000)	IS:3025 (Part 16) 2023
6	Total Hardness as CaCO <sub>3</sub>	266.77	mg/l	200 (Max. 600)	IS:3025 (Part 21) 2009
7	Calcium as Ca <sup>++</sup>	50.21	mg/l	75 ((Max. 200)	IS:3025 (Part 40) 1991
8	Magnesium as Mg <sup>++</sup>	34.31	mg/l	30 (Max.100)	IS:3025 (Part 46) 1994
9	Total Alkalinity as CaCO <sub>3</sub>	312.0	mg/l	200 (Max. 400)	IS:3025 (Part 23) 1986
10	Chloride as Cl <sup>-</sup>	28.50	mg/l	250 (Max.1000)	IS:3025 (Part 32) 1988
11	Total Iron as Fe	0.14	mg/l	1.0 (No Relax.)	IS:3025 (Part 53) 2003
12	Nitrate as NO <sub>3</sub> <sup>-</sup>	BLQ (LOQ=1.0)	mg/l	45 (No Relax.)	IS:3025 (Part 34) 1988
13	Sulphate as SO <sub>4</sub> <sup>-</sup>	14.18	mg/l	200 (Max. 400)	IS:3025 (Part 24) 2022
14	Fluoride as F <sup>-</sup>	0.6	mg/l	1.0 (Max. 1.5)	IS:3025 (Part 60) 2008
15	Free Residual Chlorine	BLQ (LOQ=0.14)	mg/l	0.2 (Max. 1.0)	IS:3025 (Part 26) 2021

BLQ=Below Limit of Quantification, LOQ= Limit of Quantification

Checked By   
**Principal**  
**New Standard Public School**  
**Sr. Sec. School**  
**Tripula Raebareli**



\*\*\*End of Report\*\*\*

(Surya Bhan Singh)  
Authorized Signatory  
**MANAGER**  
**New Standard Public School**  
**Tripula, Raebareli**

◆ The test-results relate only to the sample analyzed. ◆ The test-results may not be reproduced except in full, without a written approval of the laboratory and cannot be used as an evidence in the court of law. ◆ The sample will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. ◆ Complaints pertaining to this test report should be communicated within 7 days of issue of test report. ◆ All disputes subject to Lucknow Jurisdiction.

Doc. No.: URLS/QP/13/F-01

Page No.: 1 of 1

An ISO 9001:2015 & ISO/IEC 17025:2017 NABL Accredited Laboratory

+91-9450387301, +91-9569922950  
info@universalresearchlab.com

universalresearchlab.com

Ground Floor-Raj Market, Deva Road, Ganeshpur- Rehmanpur, Chinhat, Lucknow-226028






TEST REPORT

Sample Code: URLS24-0434		Issued On: 15.04.2024
1.	Name & Address of Customer	New Standard Public School Senior Secondary School ; Tripula Chauraha, Raebareli Uttar Pradesh.
2.	Reference No.	TRF-0242; Dated 11.04.24
3.	Material Identification with Details	Water; 1 Litre.
4.	Source / Location	Ground Water/ Tank- School Permise
5.	Sampled by / Sample Condition	Customer / Sealed & Satisfactory
6.	Sampling Plan & Procedure	NA
7.	Date / Time of Sampling	NA
8.	Date of Sample Registration	11.04.2024
9.	Date of Sample Testing	12.04.2024 to 15.03.2024
10.	Environmental Conditions	Room Temperature (°C): 24.6   Relative Humidity (%): 47

RESULTS

S. No.	Name of Test	Test Result	IS 10500:2012 Drinking Water Specification	Method of Test
Discipline- Biological				
Group- Water				
1	Total Coliform (MPN/100ml)	Not Detected	Shall not be detectable	IS:1622-1981
2	Faecal Coliform (MPN/100ml)	Not Detected	Shall not be detectable	IS:1622-1981
3	E.coli in 100 ml Sample	Not Detected	Shall not be detectable	IS:1622-1981

  
Principal  
New Standard Public School  
Sr. Sec. School  
Tripula-Raebareli

  
Checked By



  
MANAGER  
New Standard Public School  
Tripula, Raebareli

  
(Surya Bhan Singh)  
Authorized Signatory

\*\*\*End of Report\*\*\*

⊕The test-results relate only to the sample analysed. ⊕The test-results may not be reproduced except in full, without a written approval of the laboratory and cannot be used as an evidence in the court of law. ⊕The sample will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. ⊕Complaints pertaining to this test report should be communicated within 7 days of issue of test report. ⊕All disputes subject to Lucknow Jurisdiction.

Doc. No.: URLS/QP/13/F-01

Page No.: 1 of 1

An ISO 9001:2015 & ISO/IEC 17025:2017 NABL Accredited Laboratory

+91-9450387301, +91-9569922950  
info@universalresearchlab.com

universalresearchlab.com

Ground Floor-Raj Market, Deva Road, Ganeshpur- Rehmanpur, Chinhat, Lucknow-226028





**TEST REPORT**

Sample Code: URLS24-0436		ULR No: TC12484240000386F	Issued On: 15.04.2024
1.	Name & Address of Customer	New Standard Public School Senior Secondary School ; Tripula Chauraha, Raebareli Uttar Pradesh.	
2.	Reference No.	TRF-0242; Dated 11.04.24	
3.	Material Identification with Details	Water; 1 Litre	
4.	Source / Location	Ground Water/ Direct Submersible Pump School Permise	
5.	Sampled by / Sample Condition	Customer / Sealed & Satisfactory	
6.	Sampling Plan & Procedure	NA	
7.	Date / Time of Sampling	NA	
8.	Date of Sample Registration	11.04.2024	
9.	Date of Sample Testing	12.04.2024 to 15.03.2024	
10.	Environmental Conditions	Room Temperature (°C): 24.6	Relative Humidity (%): 47

**RESULTS**

S. No.	Name of Test	Test Result	Units	IS 10500:2012 Drinking Water Specification	Method of Test
<b>Discipline- Chemical</b>					
<b>Group- Water</b>					
1	Odour	Agreeable	-	Agreeable (No Relax.)	IS:3025 (Part 05) 2018
2	Taste	Agreeable	-	Agreeable (No Relax.)	IS:3025 (Part 08) 2023
3	Turbidity	BLQ (LOQ=0.1)	NTU	1.0 (Max. 5.0)	IS:3025 (Part 10) 1984
4	pH value	7.59	-	6.5-8.5 (No Relax.)	IS:3025 (Part 11) 2022
5	Total Dissolved Solids	358	mg/l	500 (Max 2000)	IS:3025 (Part 16) 2023
6	Total Hardness as CaCO <sub>3</sub>	266.77	mg/l	200 (Max. 600)	IS:3025 (Part 21) 2009
7	Calcium as Ca <sup>++</sup>	50.21	mg/l	75 ((Max. 200)	IS:3025 (Part 40) 1991
8	Magnesium as Mg <sup>++</sup>	34.31	mg/l	30 (Max.100)	IS:3025 (Part 46) 1994
9	Total Alkalinity as CaCO <sub>3</sub>	308.0	mg/l	200 (Max. 400)	IS:3025 (Part 23) 1986
10	Chloride as Cl <sup>-</sup>	20.90	mg/l	250 (Max.1000)	IS:3025 (Part 32) 1988
11	Total Iron as Fe	0.18	mg/l	1.0 (No Relax.)	IS:3025 (Part 53) 2003
12	Nitrate as NO <sub>3</sub> <sup>-</sup>	1.18	mg/l	45 (No Relax.)	IS:3025 (Part 34) 1988
13	Sulphate as SO <sub>4</sub> <sup>-</sup>	7.57	mg/l	200 (Max. 400)	IS:3025 (Part 24) 2022
14	Fluoride as F <sup>-</sup>	0.6	mg/l	1.0 (Max. 1.5)	IS:3025 (Part 60) 2008
15	Free Residual Chlorine	BLQ (LOQ=0.14)	mg/l	0.2 (Max. 1.0)	IS:3025 (Part 26) 2021

BLQ=Below Limit of Quantification, LOQ= Limit of Quantification

Checked By   
**Principal**  
**New Standard Public School**  
**Sr. Sec. School**  
**Tripula-Raebareli**



\*\*\*End of Report\*\*\*

(Surya Bhan Singh)  
Authorized Signatory  
**MANAGER**  
**New Standard Public School**  
**Tripula, Raebareli**

⊛The test-results relate only to the sample analysed. ⊛The test-results may not be reproduced except in full, without a written approval of the laboratory and cannot be used as an evidence in the court of law. ⊛The sample will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. ⊛Complaints pertaining to this test report should be communicated within 7 days of issue of test report. ⊛All disputes subject to Lucknow Jurisdiction.

Doc. No.: URLS/QP/13/F-01

Page No.: 1 of 1

An ISO 9001:2015 & ISO/IEC 17025:2017 NABL Accredited Laboratory

+91-9450387301, +91-9569922950  
info@universalresearchlab.com

universalresearchlab.com

Ground Floor-Raj Market, Deva Road, Ganeshpur- Rehmanpur, Chinhat, Lucknow-226028





TEST REPORT

Sample Code: URLS24-0436		Issued On: 15.04.2024
1.	Name & Address of Customer	New Standard Public School Senior Secondary School ; Tripula Chauraha, Raebareli Uttar Pradesh.
2.	Reference No.	TRF-0242; Dated 11.04.24
3.	Material Identification with Details	Water; 1 Litre.
4.	Source / Location	Ground Water/ Direct Submersible Pump School Premise
5.	Sampled by / Sample Condition	Customer / Sealed & Satisfactory
6.	Sampling Plan & Procedure	NA
7.	Date / Time of Sampling	NA
8.	Date of Sample Registration	11.04.2024
9.	Date of Sample Testing	12.04.2024 to 15.03.2024
10.	Environmental Conditions	Room Temperature (°C): 24.6   Relative Humidity (%): 47

RESULTS

S. No.	Name of Test	Test Result	IS 10500:2012 Drinking Water Specification	Method of Test
Discipline- Biological				
Group- Water				
1	Total Coliform (MPN/100ml)	Not Detected	Shall not be detectable	IS:1622-1981
2	Faecal Coliform (MPN/100ml)	Not Detected	Shall not be detectable	IS:1622-1981
3	E.coli in 100 ml Sample	Not Detected	Shall not be detectable	IS:1622-1981

  
Principal  
New Standard Public School  
Sr. Sec. School  
Tripula-Raebareli

  
MANAGER  
New Standard Public School  
Tripula, Raebareli

  
Checked By



  
(Surya Brian Singh)  
Authorized Signatory

\*\*\*End of Report\*\*\*

⊛ The test-results relate only to the sample analysed. ⊛ The test-results may not be reproduced except in full, without a written approval of the laboratory and cannot be used as an evidence in the court of law. ⊛ The sample will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. ⊛ Complaints pertaining to this test report should be communicated within 7 days of issue of test report. ⊛ All disputes subject to Lucknow Jurisdiction.

Doc. No.: URLS/QP/13/F-01

An ISO 9001:2015 & ISO/IEC 17025:2017 NABL Accredited Laboratory

Page No.: 1 of 1

+91-9450387301, +91-9569922950  
info@universalresearchlab.com

universalresearchlab.com

Ground Floor-Raj Market, Deva Road, Ganeshpur- Rehmanpur, Chinhat, Lucknow-226028





TC-12484  
**TEST REPORT**

Sample Code: URLS24-0435		ULR No: TC12484240000385F	Issued On: 15.04.2024
1.	Name & Address of Customer	New Standard Public School Senior Secondary School ; Tripula Chauraha, Raebareli Uttar Pradesh.	
2.	Reference No.	TRF-0242; Dated 11.04.24	
3.	Material Identification with Details	Water; 1 Litre.	
4.	Source / Location	Drinking Water(RO Water) / School Permise	
5.	Sampled by / Sample Condition	Customer / Sealed & Satisfactory	
6.	Sampling Plan & Procedure	NA	
7.	Date / Time of Sampling	NA	
8.	Date of Sample Registration	11.04.2024	
9.	Date of Sample Testing	12.04.2024 to 15.03.2024	
10.	Environmental Conditions	Room Temperature (°C): 24.6	Relative Humidity (%) 47

**RESULTS**

S. No.	Name of Test	Test Result	Units	IS 10500:2012 Drinking Water Specification	Method of Test
Discipline- Chemical					
Group- Water					
1	Odour	Agreeable	-	Agreeable (No Relax.)	IS:3025 (Part 05) 2018
2	Taste	Agreeable	-	Agreeable (No Relax.)	IS:3025 (Part 08) 2023
3	Turbidity	BLQ (LOQ=0.1)	NTU	1.0 (Max. 5.0)	IS:3025 (Part 10) 1984
4	pH value	7.48	-	6.5-8.5 (No Relax.)	IS:3025 (Part 11) 2022
5	Total Dissolved Solids	74.0	mg/l	500 (Max.2000)	IS:3025 (Part 16) 2023
6	Total Hardness as CaCO <sub>3</sub>	35.30	mg/l	200 (Max. 600)	IS:3025 (Part 21) 2009
7	Calcium as Ca <sup>++</sup>	4.70	mg/l	75 ((Max. 200)	IS:3025 (Part 40) 1991
8	Magnesium as Mg <sup>++</sup>	5.72	mg/l	30 (Max.100)	IS:3025 (Part 46) 1994
9	Total Alkalinity as CaCO <sub>3</sub>	28.0	mg/l	200 (Max. 400)	IS:3025 (Part 23) 1986
10	Chloride as Cl <sup>-</sup>	15.20	mg/l	250 (Max.1000)	IS:3025 (Part 32) 1988
11	Total Iron as Fe	0.26	mg/l	1.0 (No Relax.)	IS:3025 (Part 53) 2003
12	Nitrate as NO <sub>3</sub>	BLQ (LOQ=1.0)	mg/l	45 (No Relax.)	IS:3025 (Part 34) 1988
13	Sulphate as SO <sub>4</sub>	BLQ (LOQ=1.0)	mg/l	200 (Max. 400)	IS:3025 (Part 24) 2022
14	Fluoride as F <sup>-</sup>	BLQ (LOQ=0.05)	mg/l	1.0 (Max. 1.5)	IS:3025 (Part 60) 2008
15	Free Residual Chlorine	BLQ (LOQ=0.14)	mg/l	0.2 (Max. 1.0)	IS:3025 (Part 26) 2021

BLQ=Below Limit of Quantification, LOQ= Limit of Quantification

Checked By   
**Principal**  
New Standard Public School  
Sr. Sec. School  
Tripula-Raebareli



**MANAGER** (Surya Brian Singh)  
Authorized Signatory  
New Standard Public School  
Tripula, Raebareli

\*\*\*End of Report\*\*\*

⊕ The test-results relate only to the sample analysed ⊕ The test-results may not be reproduced except in full, without a written approval of the laboratory and cannot be used as an evidence in the court of law. ⊕ The sample will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified ⊕ Complaints pertaining to this test report should be communicated within 7 days of issue of test report ⊕ All disputes subject to Lucknow Jurisdiction.

Doc. No.: URLS/QP/13/F-01

Page No.: 1 of 1

An ISO 9001:2015 & ISO/IEC 17025:2017 NABL Accredited Laboratory

+91-9450387301, +91-9569922950  
info@universalresearchlab.com

universalresearchlab.com

Ground Floor-Raj Market, Deva Road, Ganeshpur- Rehmanpur, Chinhat, Lucknow-226028






TEST REPORT

Sample Code: URLS24-0435		Issued On: 15.04.2024
1.	Name & Address of Customer	New Standard Public School Senior Secondary School ; Tripula Chauraha, Raebareli Uttar Pradesh.
2.	Reference No.	TRF-0242; Dated 11.04.24
3.	Material Identification with Details	Water; 1 Litre.
4.	Source / Location	Drinking Water(RO Water) / School Permise
5.	Sampled by / Sample Condition	Customer / Sealed & Satisfactory
6.	Sampling Plan & Procedure	NA
7.	Date / Time of Sampling	NA
8.	Date of Sample Registration	11.04.2024
9.	Date of Sample Testing	12.04.2024 to 15.03.2024
10.	Environmental Conditions	Room Temperature (°C): 24.6   Relative Humidity (%): 47

RESULTS


S. No.	Name of Test	Test Result	IS 10500:2012 Drinking Water Specification	Method of Test
Discipline- Biological				
Group- Water				
1	Total Coliform (MPN/100ml)	Not Detected	Shall not be detectable	IS:1622-1981
2	Faecal Coliform (MPN/100ml)	Not Detected	Shall not be detectable	IS:1622-1981
3	<i>E.coli</i> in 100 ml Sample	Not Detected	Shall not be detectable	IS:1622-1981

  
Principal  
New Standard Public School  
Sr. Sec. School  
Tripula-Raebareli

  
MANAGER  
New Standard Public School  
Tripula, Raebareli

  
Checked By



  
(Surya Bhan Singh)  
Authorized Signatory

\*\*\*End of Report\*\*\*

⊕ The test-results relate only to the sample analysed. ⊕ The test-results may not be reproduced except in full, without a written approval of the laboratory and cannot be used as an evidence in the court of law. ⊕ The sample will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. ⊕ Complaints pertaining to this test report should be communicated within 7 days of issue of test report. ⊕ All disputes subject to Lucknow Jurisdiction.

Doc. No.: URLS/QP/13/F-01

An ISO 9001:2015 & ISO/IEC 17025:2017 NABL Accredited Laboratory

Page No.: 1 of 1

+91-9450387301, +91-9569922950  
info@universalresearchlab.com

universalresearchlab.com

Ground Floor-Raj Market, Deva Road, Ganeshpur- Rehmanpur, Chinhat, Lucknow-226028